Table 4.4-1
MINIMUM DISTANCES FOR SITING WASTE DISPOSAL SYSTEMS (in feet)

Facility	Domestic Well	Public Well	Perennial Stream[1]	Drainage Course or Ephemeral Stream[2]
Septic tank or sewer line	50	50	50	25
Leaching field	100	100	100	50
Seepage pit	150	150	100	50

continued...

Facility	Fill Bank[3]	Cut or Property Line[4]	Lake or Reservoir[5]	
Septic tank or sewer pit	10	25	50	
Leaching field	4h	50	200	
Seepage pit	4h[6]	75	200	

[1]As measured from the line which defines the limit of a 100-year-frequency flood.

[2]As measured from the edge of the channel.

[3] Distance in feet equals four times the vertical height of the cut or fill bank. Distance is measured from the top edge of the bank.

[4] Distance in feet from property line of any neighboring lot on which individual well(s) are used. (Distances are to property lines of neighboring lots, i.e., not street easements)

[5] As measured from the high water line. (Regional Board Resolution No. 82-6 defines the high water line for Eagle Lake, Eagle Drainage Hydrologic Area as 5117.5 feet, a definition used in prohibiting the discharge of wastes from subsurface disposal systems on a lot with an elevation of less than 5130 feet. See Section 4.1 of this Basin Plan for waste discharge prohibitions for Eagle Lake.)

[6] As measured from the high seepage level.